

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

November 29, 2018

Kristina Kolodzey
Little Saints Preschool
43W301 Plank Road
Hampshire, IL 60140

Workorder: 1811B97

TEL: (847) 464-5134

FAX:

RE: Drinking Water Lead Analysis

Dear Kristina Kolodzey:

Suburban Laboratories, Inc. received 18 sample(s) on 11/15/2018 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Little Saints Preschool

Report Date: November 29, 2018

Project Name: Drinking Water Lead Analysis

Workorder: 1811B97

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1811B97-001A	1 KITCHEN A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/27/2018
1811B97-002A	1 KITCHEN B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-003A	2 KITCHEN A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-004A	2 KITCHEN B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-005A	3 KITCHEN A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-006A	3 KITCHEN B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-007A	4 KITCHEN A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-008A	4 KITCHEN B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-009A	1 6B A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-010A	1 6B B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-011A	2 6B A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-012A	2 6B B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-013A	1 BB A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-014A	1 BB B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-015A	2 BB A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-016A	2 BB B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-017A	CLASSROOM A	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/26/2018
1811B97-018A	CLASSROOM B	ND	2.00	µg/L	11/14/18 13:30	11/15/2018	11/27/2018